

<b>AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT</b>		1. CONTRACTOR ID CODE J	PAGE 1	OF 2	PAGES 2
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 11 APRIL 2005	4. REQUISITION/PURCHASE REQ. NO. N55236-05-R-0597		
6. ISSUED BY: SOUTHWEST REGIONAL MAINTENANCE CENTER BOX 368119 CODE 410 33755 BRINSER ST STE 1 SAN DIEGO, CA 92136-5299		CODE N55236	7. ADMINISTERED BY (If other than Item 6) CODE		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, State, & Zip Code)			(√)	9A. AMENDMENT OF SOLICITATION NO. N55236-05-R-0007	
			X	9B. DATED (SEE ITEM 11) 15 MARCH 2005	
				10A. MODIFICATION OF CONTRACT/ ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of offers ☐ is changed, ☒ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
(a) By completing Items 8 and 15, and returning 2 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or  
(c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation & this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS / ORDERS,  
IT MODIFIES THE CONTRACT / ORDER NO. AS DESCRIBED IN ITEM 14.**

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
B. THE ABOVE NUMBERED CONTRACT / ORDER NO. IS MODIFIED TO REFLECT ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is, ☐ is not required to sign this document and return \_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT / MODIFICATION (Organized by UFC section headings, including solicitation/contract subject matter where feasible.)

REF: USS VINCENNES (CG-49)

(SEE CONTINUING PAGES)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or Print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or Print)	
15B. CONTRACTOR / OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED

1) REQUEST FOR SPECIFICATION CLARIFICATION

**QUESTION:** WORK ITEM 992-11-002, PARA 3.9 DIRECTS THE CONTRACTOR TO PROVIDE & MAINTAIN ONE (1) 150 PSI, 1000 GPM FIRE PUMP FOR THIS AVAILABILITY. IF THE SHIP IS TO BE WORKED AT THE MOLE PIER CAN THE CONTRACTOR TIE INTO THE PIER'S FIRE SYSTEM IN LIEU OF PROVIDING THE FIRE PUMP?

**ANSWER:** THE CONTRACTOR CANNOT TIE INTO THE PIER'S FIRE SYTEM. THE WATER PRESURE AT NAVAL STATION CAN'T BE MAINTAINED AT 150 PSI, AT 1000 GPM. ALSO THE PUMP WILL BE USED WHILE INSTALLING SEA VALVE BLANKING.

**QUESTION:** COULD YOU TELL ME WHERE I CAN PICK-UP OR VIEW THE FOLLOWING REFERENCES; S9086-BS-STM-010/CH-050 READINESS AND CARE OF INACTIVE SHIPS, PM 602-016 SPOR TOWING INFORMATION, ATTACHMENT "A" OF ITEM 436-11-001.

**ANSWER:** NAVAL STATION TECHNICAL LIBRARY, BUILDING 36.